

PLEASANT VALLEY

PWSID # 0060009

Community Water System • Carroll County, Maryland

2006 Annual Water Quality Report

This is an annual report on the quality of water delivered by the Carroll County Bureau of Utilities, Department of Public Works. This report meets the Federal Safe Drinking Water Act (SDWA) requirement for "Consumer Confidence Reports" and contains information on the source of the water, its constituents, and the health risks associated with any contaminants. Safe water is vital to the community. Please read this report carefully and, if you have questions, call the Bureau of Utilities at 410-386-2164.



Pleasant Valley 2006 Annual Water Quality Report

RESORTED

First Class Mail
U.S. POSTAGE
PAID ONE OUNCE
Permit No. 364
WESTMINSTER, MD
21157

Bureau of Utilities
Department of Public Works
225 North Center Street, Room 218
Westminster, Maryland 21157


Water Source

The source of Pleasant Valley's water supply, which services the Pleasant Valley Community, is an unconfined fractured-rock aquifer. The Pleasant Valley area, underlain by the Upper Pelitic Schist, is in the Wissahickon Formation.

The groundwater wells are not under the influence. Well No. 2, producing up to 16 gallons per minute (gpm), has been the primary source of water since March 2001, under Water Appropriation Permit No. CL95G053(02). It is located 750 feet northeast of Halter Road, directly behind 1340 Pleasant Valley Road.

A source water assessment was performed and the susceptibility analysis of Pleasant Valley's water supply is based on the water quality data, potential sources of contamination, aquifer characteristics, and well integrity. The assessment determined that Pleasant Valley's water supply is susceptible to contamination by nitrates and Radon-222. The water supply is not susceptible to volatile organic compounds or synthetic organic compounds. Copies of the source water assessment are available at the Bureau of Utilities, Carroll County Government, 225 North Center Street, Room 218, Westminster, MD 21157.

Pleasant Valley Treatment Process



(continued)

(continued)

Important Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- (A) **Microbial Contaminants**, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- (B) **Inorganic Contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- (C) **Pesticides and Herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- (D) **Organic Chemical Contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- (E) **Radioactive Contaminants**, which can be naturally-occurring or the result of oil and gas production and mining activities.


In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Cryptosporidium and Radon Information

In 1999, Pleasant Valley Community Water System tested for and did not detect *Cryptosporidium* in the water. *Cryptosporidium* is a microbial pathogen found in surface water throughout the U.S. Although filtration removes *Cryptosporidium*, the most commonly used filtration methods cannot guarantee 100 percent removal. Current test methods do not allow us to determine if the organisms are dead or if they are capable of causing disease. Ingestion of *Cryptosporidium* may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. Immuno-compromised people are at greater risk of developing life-threatening illness. We encourage immuno-compromised individuals to consult their doctor regarding appropriate precautions to take to avoid infection. *Cryptosporidium* must be ingested to cause disease and it may be spread through means other than drinking water.

The Bureau of Utilities tested for Radon in 2005. The water showed an average Radon level of 4,172 picocuries per liter (pCi/L). The U. S. Environmental Protection Agency (EPA) is preparing a regulation which will specify a Maximum Contaminant Level for Radon, proposed at a range of 300 - 4,000 pCi/L. Radon is a radioactive gas that you can't see, taste, or smell. It is



(continued on next page)

Water Quality Table

Inorganic Contaminants	Date Tested	Unit	MCL	MCLG	Detected Level	Range	Major Sources
Copper ¹	2004	ppm	AL=1.3	1.3	0.38	0.035 - .38	Corrosion of household plumbing systems; erosion of natural deposits
Lead ²	2004	ppb	AL=15	0	3	<2. - 3.0	Corrosion of household plumbing systems; erosion of natural deposits
Nitrate ³	2006	ppm	10	10	5.5	4.5 - 5.5	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Microbiological Contaminants	Date Tested	Unit	MCL	MCLG	Detected Level	Range	Major Sources
Turbidity ⁴	2006	NTU	TT	na	.43	.05 - .43	Soil runoff

Disinfectants & Disinfection By-Products	Date Tested	Unit Tested	MCL	MCLG	Detected Level	Range	Major Sources
TTHMs ⁵	06/29/04	ppb	80	na	7.31	—	By-product of drinking water disinfection
HAA5 ⁵	06/29/04	ppb	60	na	ND	--	By-product of drinking water chlorination

Secondary Inorganic Chemical Parameters	Date Tested	Unit	SMCL	MCLG	Detected Level	Range	Major Sources
pH ⁶	2006	pH Units	na	na	8.1	6.8 - 8.1	Erosion of natural deposits; algae blooms

Synthetic Organic Contaminants (including pesticides and herbicides)	Date Tested	Unit	MCL	MCLG	Detected Level	Range	Major Sources
Di (2-ethylhexyl) phthalate	06/29/04	ppb	6	0	0.2	-	Discharge from rubber and chemical factories

Key to Table

AL = Action Level
MCL = Maximum Contaminant Level
SMCL = Secondary Maximum Contaminant Level
* Indicates SMCL
MCLG = Maximum Contaminant Level Goal
na = Not Applicable

pCi/L = picocuries per liter (a measure of radioactivity)
ppm = parts per million, or milligrams per liter (mg/L)
ppb = parts per billion, or micrograms per liter (µg/L)
NTU = Nephelometric Turbidity Units
TT = Treatment Technique
ND = No detect

found throughout the United States and can move up through the ground and into a home through cracks and holes in the foundation. Radon can build up to high levels in all types of homes. Radon can also get into indoor air when released from tap water from showering, washing dishes, and other household activities. Compared to Radon entering the home through soil, Radon entering the home through tap water will, in most cases, be a small source of Radon in indoor air. Radon is a known human carcinogen. Breathing air containing Radon can lead to lung cancer. Drinking water containing Radon may also cause increased risk of stomach cancer. If you are concerned about Radon in your home, test the air in your home. Testing is inexpensive and easy. Fix your home if the level of Radon in your air is four picocuries per liter of air (pCi/L) or higher. There are simple ways to fix a Radon problem that aren't too costly. For additional information, call your State Radon program or call EPA's Radon Hotline at (800-SOS-RADON).

(continued on back page)

An Explanation of the Water Quality Data Table

The water is tested to assure that it is safe and healthy. The column marked "Detected Level" shows the highest test results during the year. "Major Sources" shows where this substance usually originates. Footnotes explain important details. The State allows the County to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the Pleasant Valley data, though representative, is more than one year old.

Important Drinking Water Definitions

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Detected Level: The highest level detected of a contaminant for comparison against the acceptance levels for each parameter. These levels could be the highest single measurement, or an average of values depending on the contaminant.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Range: The lowest to the highest values for all samples tested for each contaminant. If only one sample is tested, or no range is required for this report, then no range is listed for that contaminant in the table.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Water Quality Table Footnotes

¹ The samples tested for Copper did not exceed the current action level of 1.3 ppm.

² The samples tested for Lead did not exceed the current action level of 15 ppb.

³ Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.

⁴ Turbidity is a measure of the cloudiness of water.

⁵ Although there is no collective MCLG for this contaminant group, there are individual MCLGs for some of the individual contaminants:

- Haloacetic acids: dichloroacetic acid (zero); trichloroacetic acid (0.3 mg/L)
- Trihalomethanes: bromodichloromethane (zero); bromoform (zero); dibromochloromethane (0.06 mg/L)

⁶ pH is shown as a monthly average

For additional information, contact Mr. Gregory Wantz, Water Treatment Plant Superintendent, Bureau of Utilities, Department of Public Works, at 410-386-2164; or consult our web site at ccgov.carr.org/utility. For further information, see U.S. Environmental Protection Agency (EPA) water information at www.epa.gov/safewater/ccr1.html; and, www.waterdata.com for Water Quality Data on other community water systems throughout the United States; or by calling EPA's Safe Drinking Water Hotline at 1-800-426-4791.

For billing information, call 410-386-2000, and for Operation and Maintenance inquiries, call 410-386-2164, Monday through Friday from 8:00 a.m. until 5:00 p.m. An answering machine is available after hours.

The Board of Carroll County Commissioners meets regularly with Department staff. The Carroll County Commissioners' weekly agenda is available on the Internet at ccgov.carr.org/meetings/index.html or by calling the Commissioners Office at 410-386-2043. The Carroll County Commissioners welcome and encourage public participation.



Member: American Water Works Association (AWWA)
Chesapeake Section of the American Water Works Association (CSAWWA)
Maryland Rural Water Association
Water Environment Federation (WEF)
Chesapeake Water Environment Association (CWEA)
Water and Waste Operators Association (WWOA)



PLEASANT VALLEY COMMUNITY WATER SYSTEM
Printed on Recycled Paper
CCR 2006 PV

